



County of Roanoke

FINANCE DEPARTMENT PURCHASING DIVISION

Dawn M. Rago, Buyer
5204 Bernard Drive SW, Suite 300 F
Roanoke VA 24018
(540) 283-8150
(540) 561-2827 – Fax
drago@roanokecountyva.gov

October 26, 2017

RFP # 2018-024 SCBA Compressor, Storage System & Fill Station

ADDENDUM NO. 2

Answers to Questions

Due Date & Time:
November 1, 2017 3:00PM
(Local Prevailing Time)

RFP # 2018024
SCBA Compressor, Storage System & Fill Station
ADDENDUM NO. 2

Outline of Changes – Please see below answers to question received

Scope of Work: Section -B

The bid indicates that the minimum CFM is 8. The next paragraph indicates you want 6000 psi ASME cylinders.

An 8 CFM compressor will not pump to 6000 psi. It is only capable of 5000 psi. Also, an 8 CFM compressor

Seems small for a department of your size. Should the compressor size be increased to 13 CFM or is 8 CFM your minimum?

Answer: This is an absolute minimum does not have to be what is offered to the County of Roanoke.

Optional Equipment:

#3. Price on RFID on the fill containment station.

Can this be a price on an integrated compressor & fill station with RFID?

Answer: Certainly, if you want to price the system separately with and without the RFID, that would be fine. The point of this option is to evaluate the cost of adding the RFID reader and deciding if it would be cost effective to purchase that additional feature.

#4. Price on (4) vertical mounted ASME storage cylinders, with a corresponding cascade valve Arrangement on the fill station panel. How many positions do you want on the fill station (1, 2 or 3)?

Answer: A minimum of two cylinder fill positions, just like on the system without the cascade. What we are looking for here is, how much would it cost to add extra storage cylinders (for a total of four or so) and a set of cascade valves (which allows each storage cylinder to be turned on and off individually).

**RFP # 2018024
SCBA Compressor, Storage System & Fill Station
ADDENDUM NO. 2**

IMPORTANT

*****Please sign and return with your bid package*****

REMAINDER OF PAGE INTENTIONALLY LEFT BLANK

Sign Name:

Print Name:

Date: