



# County of Roanoke

## FINANCE DEPARTMENT PURCHASING DIVISION

Dawn M. Rago, Buyer  
5204 Bernard Drive SW, Suite 300 F  
Roanoke VA 24018  
(540) 283-8150  
(540) 561-2827 – Fax  
[drago@roanokecountyva.gov](mailto:drago@roanokecountyva.gov)

January 30, 2018

### **IFB #2018-053 Lila Drive Improvements**

#### **ADDENDUM NO. 2**

##### **Questions**

Due Date & Time:  
**February 13, 2018 2:00PM**  
**(Local Prevailing Time)**

**IFB #2018-053  
Lila Drive Improvements**

1. There is currently no line markings on Lila Drive itself. Will any be required (stop bars, center lines, etc.)?

Answer: There are currently no traffic markings on Lila Dr. and we did not propose any additional markings.

2. On page C-2 of the plans, the plans reference "*proposed 24" culvert*" for Culvert 2. On page C-4, the Culvert 2 profile states the pipe is to be 18" HDPE pipe. Which is the correct diameter and pipe type?

Answer: There are currently no traffic markings on Lila Dr. and we did not propose any additional markings.

3. The existing drainage pipe that is to be abandoned, will anything need to be done to the pipe such as crushing or filling it?

Answer: The drawings indicate that the existing pipe under Lila Dr. is to be replaced in the same location at the existing culvert.

4. Is there a designated staging area?

Answer: No

5. The curb being removed is painted yellow. Will any on the new curb be painted?

Answer: The curb being removed was painted during the recent pavement overlay by the bank. We should replace the curb in kind so the new curb should be painted yellow.

\*\*\*IMPORTANT\*\*\*

\*\*\*\*\*Please sign and return with your bid package\*\*\*\*\*

REMAINDER OF PAGE INTENTIONALLY LEFT BLANK

---

Sign Name:

---

Print Name:

---

Date: