



# County of Roanoke

## FINANCE DEPARTMENT PURCHASING DIVISION

Kate Hoyt, Buyer  
5204 Bernard Drive SW, Suite 300 F  
Roanoke VA 24018  
(540) 283-8149  
(540) 561-2829 – Fax  
[khoyt@roanokecountyva.gov](mailto:khoyt@roanokecountyva.gov)

February 8, 2018

### **IFB # 2018-051 Dishwasher Equipment for Roanoke County Public Schools**

#### **ADDENDUM NO. 1**

#### **Pre-Bid Meeting Notes**

Due Date & Time:  
**February 21, 2018, 2:00 PM**  
**(Local Prevailing Time)**

**IFB # 2018-051  
DISHWASHER FOR RCPS  
ADDENDUM NO. 1**

1. **Pre-Bid Meeting Notes** – Please see the following notes, confirmations, and further specifications as discussed at the mandatory pre-bid meeting held at Back Creek Elementary on February 5, 2018. Bids submitted shall abide by any new information contained below in order to be considered compliant with IFB 2018-051.
  - a) The height of the replacement dishwasher unit door opening should be 27” allow for sheet pans to be washed, per the original specifications included in IFB 2018-051.
  - b) The length of the clean dish table should be extended as discussed in the meeting. The under shelf of this table should also be extended the full length of the new table.
  - c) A full length under shelf should be provided on the soiled dish table side as well.
  - d) The successful bid shall include all electrical work and plumbing.
  - e) The successful bid shall include an external booster heater equivalent to the existing unit.
  - f) Stainless steel tables should be 14 gauge. Please note that this is a change from the 16 gauge specified in the original documents.
  - g) The window fitting should be reinstalled as-is.
  - h) Roanoke County Schools intend to award and proceed with this replacement as soon as possible following the closing of this IFB 2018-051. There is no intention to delay the work until the summer holiday.
  - i) The scrap bin in the current sink unit shall stay on-site (should not be removed and/or disposed of).

REMAINDER OF PAGE INTENTIONALLY LEFT BLANK