



ROANOKE COUNTY

Purchasing Division

5204 Bernard Drive, Suite 300-F, P.O. Box 29800
Roanoke, Virginia 24018-0798
TEL: (540) 772-2061 FAX: (540) 772-2074

March 4, 2021

ADDENDUM NO. 1 TO ALL BIDDERS/OFFERRORS:

Reference – IFB 2021-078

Description: Temperature/Service Monitoring System for Refrigeration Units

Issue Date: February 26, 2021

Proposal Due: March 15, 2021

The above Project is hereby changed as addressed below:

1. Responses to Bidder Questions – Please see below for a list of questions received by prospective bidders, and the responses provided by Roanoke County/Roanoke County Public Schools, as we are able.
 - a. Is there WiFi or wired LAN available at each facility?
Yes; WiFi is available at each facility.
 - b. Will the school allow access to the internet (WiFi/Ethernet) for the gateways/hubs to connect to or the vendor is required to provide LTE enabled solution?
RCPS will allow connectivity to ethernet. If an ethernet data drop is needed, it will need to be pulled to the nearest data closet and will be the responsibility of the vendor. Wireless options must be capable of accepting a security certificate provided by RCPS in order to access the WiFi network.
 - c. What are the temperature thresholds for both freezers and refrigerators?
*Refrigeration units: 34-36 degrees Fahrenheit, with reporting over 36 degrees Fahrenheit.
Freezer units: 0-10 degrees Fahrenheit, with reporting over 10 degrees Fahrenheit.*
 - d. Is there a NIST or any other certification requirement for the sensors?
There is no NIST requirement.
 - e. Would the school administration want a self-installed solution, or need the vendor to provide installation services?
Installation must be completed by the successful bidder.

- f. Is there a current solution that is intended to be replaced? If yes, can you elaborate?
There is no current monitoring system in place.
- g. How many users will need access to the mobile and web app?
Access is needed for an estimated thirty (30) users.
- h. Is there any OS preference for mobile applications (e.g. iOS or Android)?
Mobile applications should be available for both iOS and Android platforms.

Note: A signed acknowledgment of this addendum must be received at the location indicated on the original solicitation either prior to the proposal due date or attached to your proposal. Signature on this addendum does not substitute for your signature on the original proposal/bid document. The original proposal/bid document must be signed.

Thank you,

Kate Hoyt
Phone: (540) 283-8149
KHoyt@roanokecountyva.gov

Sign Name:

Print Name:

Name of Firm:

Date: