



ROANOKE COUNTY

Purchasing Division

5204 Bernard Drive, Suite 300-F, P.O. Box 29800
Roanoke, Virginia 24018-0798
TEL: (540) 772-2061 FAX: (540) 772-2074

August 26, 2021

ADDENDUM NO. 1 TO ALL BIDDERS/OFFERRORS:

Reference – IFB # 2022-015

Description: Brambleton Recreation Center Boiler Replacement

Issue Date: August 18, 2021

Proposal Due: August 31, 2021

The above Project is hereby changed as addressed below:

1. Revised Pump Information – The following revised information replaces the following pumps as listed under Mechanical Equipment on Sheet M-2.
 - a. PUMP HWP-1: INLINE CIRCULATOR, 1750 RPM, 1-3/4 HP, 208 VOLT, 3 PHASE. CONTRACTOR TO FIELD VERIFY SIZE REQUIRED.
 - b. PUMP HWP-2: INLINE CIRCULATOR, 1750 RPM, 3/4 HP, 208 VOLT, 3 PHASE. CONTRACTOR TO FIELD VERIFY SIZE REQUIRED.
 - c. PUMP HWP-3: INLINE CIRCULATOR, 1750 RPM, 1 HP, 208 VOLT, 3 PHASE. CONTRACTOR TO FIELD VERIFY SIZE REQUIRED.
 - d. PUMP HWP-4: INLINE CIRCULATOR, 1750 RPM, 3/4 HP, 208 VOLT, 3 PHASE. CONTRACTOR TO FIELD VERIFY SIZE REQUIRED.
 - e. PUMP HWP-5: INLINE CIRCULATOR, 1750 RPM, 1/4 HP, 120 VOLT, 1 PHASE. CONTRACTOR TO FIELD VERIFY SIZE REQUIRED.

Note: A signed acknowledgment of this addendum must be received at the location indicated on the original solicitation either prior to the proposal due date or attached to your proposal. Signature on this addendum does not substitute for your signature on the original proposal/bid document. The original proposal/bid document must be signed.

Thank you,

Kate Hoyt
Phone: (540) 283-8149
KHoyt@roanokecountyva.gov

Sign Name:

Print Name:

Name of Firm:

Date: