



County of Roanoke

FINANCE DEPARTMENT PURCHASING DIVISION

Dawn M. Rago, Senior Buyer
5204 Bernard Drive SW, Suite 300 F
Roanoke VA 24018
(540) 283-8150
(540) 561-2827 – Fax
drago@roanokecountyva.gov

March 24, 2022

RFP #2022-054

HVAC Rooftop Units for Western Virginia Regional Jail

for

Roanoke Salem Jail

ADDENDUM NO. 3

Questions and Due Date Change
Due Date & Time:
April 8, 2022 2:00PM
(Local Prevailing Time)

Addendum No. 3
RFP 2022-054
HVAC Rooftop Units for Western Virginia Regional Jail

1. Due date is hereby changed to April 8, 2022 at 2:00 PM.
2. If Western Virginia Regional Jail accepts a turn key project the Vendor will be responsible for permits and the cost of the permits. The Vendor will also be responsible for an engineering plan to determine if the roof can hold the new unit. However, if the new units are the same weight or less a structural plan will not be necessary for submitting to obtain the permit.
3. Will you accept equipment with no reheat coil on the above referenced proposal?
Answer: We cannot accept equipment without the reheat coil if they cannot guarantee that the equipment will adequately dehumidify the spaces without it. Is there an add on feature that would help achieve dehumidification without the re-heat coil?
4. What is the date to commence ordering the equipment? Most manufacturer's, due to the current volatile marketplace, have extended lead times.
Answer: We understand that everything has extended wait times right now. We would like an estimated arrival time on the equipment offered.

*****REQUIRED*****

*****Sign and return with your bid package*****

Sign Name:

Print Name:

Date:

Company

REMAINDER OF PAGE INTENTIONALLY LEFT BLANK