



# ROANOKE COUNTY

## Purchasing Division

5204 Bernard Drive, Suite 300-F, P.O. Box 29800  
Roanoke, Virginia 24018-0798  
TEL: (540) 772-2061 FAX: (540) 772-2074

October 10, 2024

### ADDENDUM NO. 1 TO ALL BIDDERS/OFFERRORS:

Reference – IFB 2025-028

Description: Roanoke County Storm Drainage Improvements

Issue Date: September 17, 2024

Proposal Due: October 21, 2024

The above Project is hereby changed or clarified as addressed below:

#### **General:**

1. Temporary fencing for dogs will be installed and removed by Roanoke County. Contractor shall coordinate with his work and schedule.
2. Bedding stone and miscellaneous items shall be provided by the Contractor for pipe and structures supplied by Roanoke County.
3. Invert shaping is required for all structures.

#### **Tully Drive:**

1. Milling will be paid for by the square yard. Design intent is to mill to match overlay to existing at limits of construction. Asphalt will be paid for by the ton. See Revised Bid Form included in this Addendum.
2. The two 48" maple trees shown on the plans in the back yard of 2737 Tully Drive will need to be removed. These trees will need to be removed between the dates of November 16<sup>th</sup> and March 31<sup>st</sup>.
3. The asphalt section for the private driveway shall consist of 6" #21A stone base and 2" SM-9.5A.
4. Trenches in VDOT R/W shall be full stone backfill with #21A or #21B from the bottom of the trench to the bottom of proposed asphalt.
5. Any curb in VDOT R/W not part of a private driveway will need to be per VDOT requirements.

#### **Pebble Drive:**

1. Existing sheds shall be removed from the drainage easement as called for on the plans.
2. Project time for completion is hereby adjusted to 240 days to substantial completion, and 270 days to final completion.
3. Existing structure at upstream end of project will be supplied by Roanoke County, installed by Contractor as part of this project. The structure is constructed with openings for existing roof leaders.

**Note:** A signed acknowledgment of this addendum must be received at the location indicated on the original solicitation either prior to the proposal due date or attached to your proposal.

Signature on this addendum does not substitute for your signature on the original proposal/bid document. The original proposal/bid document must be signed.

Thank you,

Kate Hoyt  
Phone: (540) 283-8149  
[KHoyt@roanokecountyva.gov](mailto:KHoyt@roanokecountyva.gov)

---

Sign Name:

---

Print Name:

---

Name of Firm:

---

Date: